



## COMMONWEALTH of VIRGINIA

ROBERT B. STROUBE, M.D., M.P.H.  
STATE HEALTH COMMISSIONER

Department of Health  
P O BOX 2448  
RICHMOND, VA 23218

TTY 7-1-1 OR  
1-800-828-1120

December 1, 2005

Mr. Bill Coon  
President  
Coon Manufacturing  
P. O. Box 108  
Spickard, MO 64679

Dear Mr. Coon:

First of all, I want to apologize for the delay in responding to your request for approval of septic tanks manufactured by your company for use in Virginia. I have completed the review of the drawings and test reports you submitted for the tanks. The information is for 1,000 and 1,500 gallon capacity two compartment rotationally molded polyethylene tanks.

Section 12 VAC 5-610-815 of the Sewage Handling and Disposal Regulations (*Regulations*) specifies the technical requirements for a septic tank (copy attached). The technical details you submitted for the above mentioned tanks indicate that some of the criteria for dimensions of the tanks are not in full compliance of the requirements specified in the *Regulations*. However, after reviewing the test reports prepared by the Universal Laboratory, Inc., the Division of Onsite Sewage and Water Services (*Division*) approves both the tanks (1,000 gallon and 1,500 gallon) for use in Virginia if an NSF certified effluent filter is included in the outlet structure of each tank. This approval notice will be posted on the *Division's* web site as GMP #131.

If you have any questions about this letter, you may call me at 804-864-7457.

Thank you,

Sincerely,

A handwritten signature in dark ink, appearing to read "Anish R. Jantrania".

Anish R. Jantrania, Ph.D., P.E.  
Technical Services Engineer.

Attachment: Section 12 VAC 5-610-815 of the *Regulations*.